

Certificate

Applicant: **sonnen GmbH**
Am Riedbach 1
im Innovationspark Allgäu
87499 Wildpoldsried
Germany

Product: **Battery storage system**

Model:	sonnenBatterie eco 9.43/x					
	9.43/2.5	9.43/5	9.43/7.5	9.43/10	9.43/12.5	9.43/15
Rating:	1,1kW	2,5kW	3,3kW			

Intended use:

An automatic disconnection device with single-phase mains surveillance in accordance with Engineering Recommendation G83/2 for photovoltaic systems with a single-phase parallel coupling via an inverter to the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

Engineering Recommendation G83/2
Issue 2 – August 2012

Recommendations for the connection of small-scale embedded generators in parallel with public low-voltage distribution networks.

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 17PP317-05

Certificate No: 18-027-00

Date of issue: 2018-01-29



Andreas Aufmuth
Certification Department

